

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:05 pm

PWS ID: UTAH27019 **Name:** VEYO CULINARY WATER ASSN
Legal Contact: VEYO CULINARY WATER ASSN **Rating:** Approved
LARRY ANDREWS **Rating Date:** 12/09/1991
Address: 176 S SPANISH TRAIL **Activity Status:** Active
VEYO, UT 84782
Phone Number: 435-574-2758
City Served (Area):
County: WASHINGTON COUNTY
System Type: Community **Last Inv Update:** 07/05/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/06/2009 **Total Dsgn Cap:**
Population: 500 **Surveyor:** RANDY TAYLOR **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Email Address
			Office Emergency	
AC	ANDREWS, LARRY		435-574-2727	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered/Unm	0	214
			214 Total Svc Connections

Storage

Total Storage: 1,040,000 GAL **Number of Units:** 9 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST009	120K STEEL BOLTED TANK	Ground	0 GAL	Steel		P	
ST005	TWIN TANK EAST	Ground	30,000 GAL	Steel		A	NO
ST006	TWIN TANK WEST	Ground	30,000 GAL	Steel		A	NO
ST007	COTTAM ROAD TANK	Ground	500,000 GAL	Steel		A	NO
ST008	CONCRETE TANK	Ground	250,000 GAL	Concrete		A	
ST002	BROOKSIDE #1 STORAGE	Ground	50,000 GAL	Steel		A	NO
ST003	BROOKSIDE #2 STORAGE	Ground	50,000 GAL	Steel		A	NO
ST004	GREEN (BEER) TANK	Ground	50,000 GAL	Concrete		A	NO
ST001	SPRING TANK	Ground	80,000 GAL	Steel		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	VEYO SPRING CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	BROOKSIDE BOOSTER PUMP STA	A		P			
PF002	HIGH ELEVATION PARK BOOSTEF	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	VEYO SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #1	Active	WL	4		325 GPM	Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*